

DESCRIPCIÓN DEL TEST / TEST DESCRIPTION				NORMA / STANDARD	VALOR DEL TEST / TEST VALUE	EVALUACIÓN / EVALUATION
ABSORCIÓN DE AGUA / WATER ABSORPTION				UNE-EN-ISO-10545-3	Ev > 10%	CUMPLE / COMPLIES
FUERZA DE ROTURA / BREAKING STRENGTH				UNE-EN-ISO-10545-4	≥ 600 N	CUMPLE / COMPLIES
RESISTENCIA A LA FLEXIÓN / MODULUS OF RUPTURE				UNE-EN-ISO-10545-4	≥ 12 N/mm <sup>2</sup>	CUMPLE / COMPLIES
RESISTENCIA AL CUARTEO / CRAZING RESISTANCE				UNE-EN-ISO-10545-11	REQUERIDO / REQUESTED	CUMPLE / COMPLIES
RESISTENCIA QUÍMICA / CHEMICAL RESISTANCE	PRODUCTOS DOMÉSTICOS Y DE PISCINA / HOUSEHOLD CHEMICALS AND SWIMMING POOLS SALTS			UNE-EN-ISO-10545-13	MÍNIMO CLASE B / MINIMUM CLASS B	CUMPLE / COMPLIES
	ÁCIDOS A BAJA CONCENTRACIÓN / LOW CONCENTRATION ACIDS			UNE-EN-ISO-10545-13	VALOR DECLARADO / DECLARED VALUE	MÍNIMO CLASE LB / MINIMUM CLASS LB
	BASES A BAJA CONCENTRACIÓN / LOW CONCENTRATION OF ALKALIS			UNE-EN-ISO-10545-13	VALOR DECLARADO / DECLARED VALUE	MÍNIMO CLASE LB / MINIMUM CLASS LB
RESISTENCIA A LAS MANCHAS / RESISTANCE TO STAINS				UNE-EN-ISO-10545-14	MÍNIMO CLASE 3 / MINIMUM CLASS 3	CUMPLE / COMPLIES
RESISTENCIA AL RAYADO / HARDNESS (MOHS)				EN-101	VALOR DECLARADO / DECLARED VALUE	MÍNIMO 3 / MINIMUM 3